

Vendor Policies & Procedures Hillbilly Dayz Entertainment Inc.

GENERAL TERMS OF VENDOR PARTICIPATION AGREEMENT *(Keep this portion for reference)*

FESTIVAL AREA:

- The official "Festival Area " is as defined:
 - Main Street from E. Washington St. to Calhoun Street and one block back from Main at each cross street.

VENDOR SPACES

1. Vendors should have adequate protection for inclement weather and wind. **All tents need to be anchored and all electrical cords must be covered, or taped down.**
2. Applicants must submit photographs of their products and one (1) photo of their booth display.
3. To ensure variety and eliminate repetition, the festival will limit the kinds of crafts, goods, and products that will be accepted for sale at the festival. You must list products that you wish to sell.
4. Booth space is 10 ft. X 10 ft. Rental is for booth space only and does not include tables, chairs, tents, water or other items for your booth.
5. Food vendors must comply with Galax Health Department regulations. You must apply for a temporary food permit at least 15 days prior to the festival. We can provide applications, just let us know if you need one. Call Galax Health Dept. at 276.236.6127 if you have questions.

USE OF ALLOCATED SPACE(S)

1. The festival reserves the right to locate/relocate vendor booths according to the needs of the festival. Please indicate any special needs you may have when completing the application. We will do our best to fulfill your request; however, we cannot make any guarantees.
2. Vendors can sell only from their rented booth space.
3. Vendor shall comply with all laws, ordinances, rules and regulations of any lawful authority, agency or government entity which apply to the use of its vending unit requirements, including without limitation, any applicable fire and building code of the Grayson/Carroll Shriners Kazim Hillbillies, and health regulations of the Galax Health Department. The vendor accepts full responsibility for the payment of sales tax occasioned by use of booth space.

4. Vendor shall be solely responsible for any and all injuries to persons or damages to property or any other injury, claim, damage or loss of whatever nature, arising from or related to the festival. Vendor shall indemnify, save and hold harmless Hillbilly Dayz Entertainment Inc. and Galax Downtown Association, Board Members, employees, and volunteers from and against all liability, loss, damages, claims, costs and expenses (including reasonable attorney's fees) arising out of injury to person (including death) or damage to property or any other injury, claim, damage, loss, cost or expense arising from the festival performed by vendor including, but not limited to, any negligence, act or omission of vendor or weather related issues.
5. Vendor agrees to accept responsibility for all materials and goods furnished by him/her, and used or displayed in the booth area. While the festival will make reasonable efforts to provide security, the exhibitor accepts full responsibility for his/her personal property.

CARE OF ALLOCATED BOOTH SPACE

1. All vendors are responsible for keeping the area in and around their booths clean throughout the festival.
2. Vendors shall be responsible for set-up and removal of their own equipment, fixtures, inventory and other property.

SET-UP HOURS

- Friday, June 19th between the hours of 9AM - 11AM. (***NO CARS ALLOWED ON STREET AFTER 11AM***)
- Please unload your items, park your vehicle and come back to set up your booth to allow for a smooth traffic flow
- **Breakdown Time:** Saturday, June 20, 2026 at 6:00PM (*Breakdown must be complete by 7:30PM*)
- **Exhibitors agree not to take down booths before 6 pm. If you choose to tear down your booth before the end of the festival, you will need to walk your merchandise and equipment out.**
- NO vendor is allowed to set up or move into any other booth space, or open area.
- Vendors shall furnish trash containers and bags, and bag all garbage and trash on a regular basis during the festival. In summary, vendors must remove garbage, and equipment from the allocated vending space.
- **Cancellations:** If there is a need to cancel, vendors need to contact Tracy at galaxhillbillydayz@gmail.com, or call Mike Kinzer, at **276-233-8006**, as soon as possible.
- Once your application has been accepted and processed, no refunds or credits will be issued. **Festival will be held, rain or shine.**

POWER

1. Quiet Generators are permitted, but must be approved by the Festival Committee.
2. **110v electricity is available in limited quantities, and must be indicated on your vendor application. There is no guarantee of power, it is provided on a first come, first serve basis.**
3. All vendors are required to supply extension cords. (*10- or 12-gauge cords are recommended.*)
4. **Food vendors must comply with State of Virginia Fire regulations and be equipped with a fire extinguisher. All food vendors will be inspected by the Galax Fire Department.** For a list of requirements visit:
 - Virginia Building and Fire Regulations, Chapter 3, Section 19:
<https://www.dhcd.virginia.gov/building-and-fire-regulations-archives>
 - *The current, 2021, editions are included with this packet also, but are subject to update by VBFR at any time.*
5. The festival committee reserves the right to take immediate action in any situation where equipment, including electrical appliances and extension cords, appear to be substandard or unsafe.

LIABILITY

1. Hillbilly Dayz Entertainment Inc. shall not be liable for any loss or damage to the property of vendor or any of its representatives, employees, agents, patrons and guests, because of fire, robbery, accidents, or any other cause whatsoever that may arise from vendor's use or occupancy of its allocated space during the festival.
2. Vendor agrees to indemnify and hold harmless representatives, employees, and volunteers of the festival and/or Hillbilly Dayz Entertainment Inc. against any and all claims of any person whomsoever, from acts or omissions of the vendor, its representatives, employees, agents, patrons, or guests.
3. Vendor will supply Hillbilly Dayz Entertainment Inc. a certificate of liability insurance with limits of not less than \$1,000,000 Per Occurrence and \$2,000,000 Aggregate, naming Hillbilly Dayz Entertainment Inc., their directors, representatives, employees and volunteers as additional insured and including Waiver of Subrogation with respect to general liability coverage.

SECURITY

We will have security on site starting Friday, June 19, from 11 AM through Saturday, June 20, at 11 PM.

Change Section 315.6 to read:

315.6 Storage in plenums. Storage shall not be permitted in plenums unless approved for such use by the applicable building code. Abandoned material in plenums shall be deemed to be storage and shall be removed. Where located in plenums, the accessible portion of abandoned cables that are not identified for future use with a tag shall be deemed storage and shall be removed.

*The following changes shall be made to Section 316, Hazards to Fire Fighters:**Change Sections 316.6 through 316.6.2 to read:*

316.6 Structures and outdoor storage underneath high-voltage transmission lines, bridges, and elevated roadways. Structures and outdoor storage underneath high-voltage transmission lines, bridges, and elevated roadways shall comply with Sections 316.6.1 and 316.6.2, respectively.

316.6.1 Structures. Structures shall not be constructed within the utility easement beneath high-voltage transmission lines or underneath bridges or elevated roadways unless approved.

316.6.2 Outdoor storage. Outdoor storage within the utility easement underneath high-voltage transmission lines or underneath bridges or elevated roadways shall be limited to noncombustible materials. Storage of hazardous materials, including flammable and combustible liquids, is prohibited.

Exception: Combustible storage, including vehicles and fuel storage for backup power equipment serving public utility equipment or for the construction, repair, or maintenance operations of bridges or elevated roadways, is allowed provided that a plan indicating the storage configuration is submitted and approved.

*The following changes shall be made to Section 317, Landscaped Roofs:**Change Section 317.1 to read:*

317.1 General. Landscaped roofs shall be maintained in accordance with Sections 317.2 through 317.5.

Change Section 317.2 to read:

317.2 Landscaped roof size. Landscaped roof areas shall not exceed the size approved in accordance with the applicable building code.

Change Section 317.3 to read:

317.3 Rooftop structure and equipment clearance. Required structure and equipment clearances shall be maintained as provided by the applicable building code.

*The following change shall be made to Section 318, Laundry Carts:**Change Exception 1 (Exception 2 remains) of Section 318.1 to read:*

1. Laundry carts in areas protected by an approved automatic sprinkler system throughout in accordance with the applicable NFPA 13 standard.

The following changes shall be made to Section 319, Mobile Food Preparation Vehicles:

319.1 General. Mobile food preparation vehicles that are equipped with appliances that utilize open flames or produce smoke or grease laden vapors shall comply with this section.

319.1.1 Wheel chocks. Wheel chocks shall be used to prevent mobile food preparation vehicles from moving.

GENERAL REQUIREMENTS

319.1.2 Separation. Mobile food preparation vehicles shall be separated from buildings or structures, combustible materials, vehicles, and other cooking operations by a minimum of 10 ft. (3m).

319.2 Permit required. Permits shall be required as set forth in Section 107.2.

319.2.1 Permit authority having jurisdiction (AHJ). The enforcing agent of a permit requirement on a mobile food preparation vehicle (MFPV) shall be the appointed fire official for the Virginia local government to which the food truck is identified for personal property tax payment of the vehicle. If no such entity exists, if the local government has elected to not enforce this section of the SFPC, or if the MFPV is housed out of state, then it shall be the State Fire Marshal's Office (SFMO) or designee.

319.3 Seating. Seating for the public within any mobile food preparation vehicles is prohibited.

319.4 Exhaust hood. Cooking equipment that produces grease laden vapors shall be provided with a kitchen exhaust hood in accordance with NFPA 96, Annex B.

319.5 Fire protection. Fire protection shall be provided in accordance with Sections 319.5.1 through 319.5.2.

319.5.1 Fire protection for cooking equipment. Cooking equipment shall be protected by automatic fire extinguishing systems in accordance with Section 904.3.1.

319.5.2 Fire extinguisher. Portable fire extinguishers shall be provided in accordance with Section 906.4.

319.6 Appliance connection to fuel supply. Gas cooking appliances shall be secured in place and connected to fuel supply piping with an appliance connector complying with ANSI Z21.69/CSA 6.16. The connector installation shall be configured in accordance with manufacturer's installation instructions. Movement of appliances shall be limited by restraining devices installed in accordance with the connector and appliance manufacturer's instructions.

319.6.1 Construction and modifications. Following initial construction and any modifications of the fuel system, the system, including hoses, shall be proven free of leaks by performing a pressure test in accordance with NFPA 58 at not less than the normal operating pressure.

319.6.2 Leak detection. Gas systems shall be inspected prior to each use and following fuel tank replacement or refill in one of the following methods:

1. A water and soap solution shall be applied to every accessible connection or connection manipulated during the replacement or fueling and observed for evidence of gas leakage.
2. Pressure testing in accordance with Annex L of NFPA 58.

319.6.3 Leaks. When leaks are discovered during inspections and testing, the fuel supply shall be secured in the "off" position or disconnected from the appliance, and the appliance shall not be operated until serviced by a qualified person.

319.7 Cooking oil storage containers. Cooking oil storage containers within mobile food preparation vehicles shall have a minimum aggregate area volume not to exceed 120 gallons (454 L) and shall be stored in such a way as to not be toppled or damaged during transport.

319.8 Cooking oil storage tanks. Cooking oil storage tanks within mobile food preparation vehicles shall comply with Sections 319.8.1 through 319.8.5.

319.8.1 Metallic storage tanks. Metallic cooking oil storage tanks shall be listed in accordance with UL 142 or UL 80, and shall be installed in accordance with the tank manufacturer's instructions.

319.8.2 Nonmetallic tanks. Nonmetallic cooking oil storage tanks shall be installed in accordance with the tank manufacturer's instructions and shall also comply with all of the following:

1. Tanks shall be listed for use with cooking oil, including maximum temperature to which the tanks will be exposed to during use.
2. Tank capacity shall not exceed 200 gallons (757 L) per tank.

319.8.3 Cooking oil storage system components. Metallic and nonmetallic cooking oil storage system components shall include piping, connections, fittings, valves, tubing, hose, pumps, vents, and other related components used for the transfer of cooking oil.

319.8.4 Design criteria. The design, fabrication, and assembly of system components shall be suitable for the working pressures, temperatures, and structural stresses to be encountered by the components.

319.8.5 Tank venting. Normal and emergency venting shall be provided for cooking oil storage tanks.

319.8.5.1 Normal vents. Normal vents shall be located above the maximum normal liquid line and shall have a minimum effective area not smaller than the largest filling or withdrawal connection. Normal vents are not required to vent to the exterior.

319.8.5.2 Emergency vents. Emergency relief vents shall be located above the maximum normal liquid line and shall be in the form of a device that will relieve excessive internal pressure caused by an exposure fire. For nonmetallic tanks, the emergency relief vent shall be allowed to be in the form of construction. Emergency vents are not required to discharge to the exterior.

319.9 Liquefied petroleum gas (LP-gas) systems. Where LP-gas systems provide fuel for cooking appliances, such systems shall comply with NFPA 58, Chapter 61, and Sections 319.9.1 through 319.9.5.

319.9.1 Maximum aggregate volume. The maximum aggregate capacity of LP-gas containers transported on the vehicle and used to fuel cooking appliances only shall not exceed 200 pounds propane capacity.

319.9.2 Protection of container. LP-gas containers installed on the vehicle shall be securely mounted and restrained to prevent movement.

319.9.3 LP-gas container construction. LP-gas containers shall be manufactured in compliance with the requirements of NFPA 58.

319.9.4 Protection of system piping. LP-gas system piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage, and damage from vibration.

319.9.5 LP-gas alarms. A listed LP-gas alarm shall be installed with the vehicle in the vicinity of LP-gas system components, in accordance with manufacturer's instructions.

319.10 Compressed natural gas (CNG) systems. Where CNG systems provide fuel for cooking appliances, such systems shall comply with Sections 319.10.1 through 319.10.4.

319.10.1 CNG containers supplying only cooking fuel. CNG containers installed solely to provide fuel for cooking purposes shall be in accordance with Sections 319.10.1.1 through 319.10.1.3.

319.10.1.1 Maximum aggregate volume. The maximum aggregate capacity of CNG containers transported on the vehicle shall not exceed 1,300 pounds water capacity.

319.10.1.2 Protection of container. CNG containers shall be securely mounted and restrained to prevent movement. Containers shall not be installed in locations subject to direct vehicle impact.

319.10.1.3 CNG container construction. The construction of CNG containers shall be approved.

319.10.2 CNG containers supplying transportation and cooking fuel. Where CNG containers and systems are used to supply fuel for cooking purposes in addition to being used for transportation fuel, the installation shall be in accordance with NFPA 52.

319.10.3 Protection of system piping. CNG system piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage, and damage from vibration.

319.10.4 Methane alarms. A listed methane gas alarm shall be installed within the vehicle in accordance with manufacturer's instructions.

319.11 Maintenance. Maintenance of systems on mobile food preparation vehicles shall be in accordance with Sections 319.11.1 through 319.11.3.

GENERAL REQUIREMENTS

319.11.1 Exhaust system. The exhaust system, including hood, grease-removal devices, fans, ducts and other appurtenances, shall be inspected and cleaned in accordance with Chapter 6.

319.11.2 Fire protection systems and devices. Fire protection systems and devices shall be maintained in accordance with Chapter 9.

319.11.3 Fuel-gas systems. LP-gas containers installed on the vehicle and fuel-gas piping systems shall be inspected annually by an approved inspection agency or a company that is registered with the U.S. Department of Transportation to requalify LP-gas cylinders to ensure that system components are free of damage, suitable for the intended service, and not subject to leaking. CNG containers shall be inspected every three years in a qualified service facility. CNG containers shall not be used past their expiration dates listed on the manufacturer's container label. Upon satisfactory inspection, the approved inspection agency shall affix a tag on the fuel-gas system or within the vehicle indicating the name of the inspection agency and the date of satisfactory inspection.

Cambie la sección 315.6 para la lectura correspondiente:

315.6 Almacenamiento en cámaras de aire. No se debe permitir almacenamiento en cámaras de aire, a menos que el código de edificación correspondiente autorice dicho uso. El material abandonado en cámaras de aire se considerará un almacenamiento y debe retirarse. La parte accesible de los cables abandonados, que se encuentren en las cámaras de aire, y que no se identifiquen para el uso posterior mediante una etiqueta, deben considerarse almacenamiento y deben retirarse.

Se deben realizar los siguientes cambios a la sección 316, Peligros para los bomberos:

Cambie las secciones 316.6 a 316.6.2 para la lectura correspondiente:

316.6 Estructuras y almacenamiento al aire libre debajo de líneas de transmisión de alta tensión, puentes y carreteras elevadas. Las estructuras y el almacenamiento al aire libre que están debajo de las líneas de transmisión de alta tensión, puentes y carreteras elevadas deben cumplir lo dispuesto en las secciones 316.6.1 y 316.6.2, respectivamente.

316.6.1 Estructuras. No deben construirse estructuras dentro de la servidumbre de paso debajo de líneas de transmisión de alta tensión ni debajo de puentes o carreteras elevadas, a menos que estén aprobadas.

316.6.2 Almacenamiento al aire libre. El almacenamiento al aire libre dentro del área de servidumbre de paso debajo de líneas de transmisión de alta tensión o debajo de puentes o carreteras elevadas se limitará a materiales no combustibles. Se prohíbe el almacenamiento de materiales peligrosos, incluidos líquidos inflamables y combustibles.

Excepción: Se permite el almacenamiento de combustibles, incluidos los vehículos y el almacenamiento de combustible para los equipos de energía de reserva que sirven a los equipos de servicios públicos o para las operaciones de edificación, reparación o mantenimiento de puentes o carreteras elevadas, siempre que se presente y apruebe un plan que indique la configuración del almacenamiento.

Se deben realizar los siguientes cambios a la sección 317, Techos ajardinados:

Cambie la sección 317.1 para la lectura correspondiente:

317.1 Generalidades. Los techos ajardinados deben mantenerse de conformidad con las secciones 317.2 a 317.5.

Cambie la sección 317.2 para la lectura correspondiente:

317.2 Dimensiones de los techos ajardinados. Las áreas que comprenden el techo ajardinado no deben superar las dimensiones aprobadas de conformidad con el código de edificación correspondiente.

Cambie la sección 317.3 para la lectura correspondiente:

317.3 Espacio libre de la estructura de la azotea y del equipo. El espacio libre de la estructura y del equipo requerido debe mantenerse según lo dispuesto en el código de edificación correspondiente.

Se debe realizar el siguiente cambio a la sección 318, Carritos de lavandería:

Cambie la excepción 1 (permanece la excepción 2) de la sección 318.1 para la lectura correspondiente:

1. Carritos de lavandería en áreas protegidas en toda su extensión por un sistema de rociadores automáticos aprobado de acuerdo con la norma NFPA 13 correspondiente.

Se deben realizar los siguientes cambios a la sección 319, Vehículos móviles para preparación de alimentos:

319.1 Generalidades. Los vehículos móviles para preparación de alimentos que estén equipados con artefactos que utilicen llamas abiertas o produzcan humo o vapores cargados de grasa deben cumplir con lo dispuesto en esta sección.

SÓLIDOS Y LÍQUIDOS REACTIVOS AL AGUA

319.1.1 Cuñas para ruedas. Se deben usar cuñas para ruedas para evitar que los vehículos móviles para preparación de alimentos se muevan.

319.1.2 Separación. Los vehículos móviles para preparación de alimentos deben estar separados de edificaciones o estructuras, materiales combustibles, vehículos y otras operaciones de cocina por una distancia mínima de 10 pies (3 m).

319.2 Permiso requerido. Se deben requerir permisos según lo establecido en la sección 107.2.

319.2.1 Autoridad del permiso con jurisdicción (AHJ). El agente responsable del cumplimiento respecto de los requisitos de permiso para un vehículo móvil para preparación de alimentos (MFPV) debe ser el oficial de bomberos nombrado por el gobierno local de Virginia ante quien se identifica el camión de comidas para el pago del impuesto a los bienes muebles del vehículo. Si no existe dicha entidad, si el gobierno local ha elegido no implementar esta sección del SFPC o si el MFPV se encuentra ubicado fuera del estado, entonces será la oficina del jefe de bomberos del estado (SFMO) o la persona designada.

319.3 Asientos. Se prohíbe disponer de asientos para el público dentro de cualquier vehículo móvil para preparación de alimentos.

319.4 Campana de extracción. Los equipos de cocina que produzcan vapores cargados de grasa deben estar provistos con una campana de extracción para cocina de conformidad con el anexo B de la NFPA 96.

319.5 Protección contra incendios. Se debe proporcionar protección contra incendios de acuerdo con las secciones 319.5.1 a 319.5.2.

319.5.1 Protección contra incendios para equipos de cocina. Los equipos de cocina deben estar protegidos mediante sistemas automáticos de extinción de incendios de conformidad con la sección 904.3.1.

319.5.2 Extintor de incendio. Se deben proporcionar extintores de incendio portátiles de conformidad con la sección 906.4.

319.6 Conexión del artefacto al suministro de combustible. Los artefactos de cocción a gas se deben asegurar en su lugar y conectarse a las tuberías de suministro de combustible con un conector para el artefacto que cumpla con las normas ANSI Z21.69/AS 6.16. La instalación del conector debe configurarse de acuerdo con las instrucciones de instalación provistas por el fabricante. Se debe limitar la circulación de los artefactos mediante dispositivos de sujeción instalados según las instrucciones del fabricante del conector y del artefacto.

319.6.1 Construcción y modificaciones. Luego de la construcción inicial y de cualquier modificación realizada en el sistema de combustible, se debe comprobar que el sistema, incluidas las mangueras, no tiene fugas mediante una prueba de presión de conformidad con la NFPA 58, a una presión de operación no inferior a la normal.

319.6.2 Detección de fugas. Los sistemas de gas deben inspeccionarse antes de cada uso y después de que se reemplace o vuelva surtir el tanque de combustible mediante uno de los siguientes métodos:

1. Se debe aplicar una solución de agua y jabón en cada conexión accesible o conexión que se manipule durante el reemplazo o el suministro de combustible y se debe prestar atención a fin de detectar fugas de gas.
2. Pruebas de presión de conformidad con el anexo L de la NFPA 58.

319.6.3 Fugas. Cuando se detecten fugas durante las inspecciones y las pruebas, se debe asegurar el suministro de combustible en la posición de "apagado" o desconectar del artefacto y dicho artefacto no debe accionarse hasta que una persona acreditada lo revise.

319.7 Contenedores para almacenamiento de aceite de cocina. Los contenedores para almacenamiento de aceite de cocina dentro de los vehículos móviles para preparación de alimentos deben tener un volumen de área total mínimo que no exceda los 120 galones (454 l), y almacenarse de forma que no se vuelquen ni dañen durante el desplazamiento.

319.8 Tanques de almacenamiento de aceite de cocina. Los tanques de almacenamiento de aceite de cocina dentro de los vehículos móviles para preparación de alimentos deben cumplir con las secciones 319.8.1 a 319.8.5.

319.8.1 Tanques metálicos de almacenamiento. Se debe hacer un listado de los tanques metálicos de almacenamiento de aceite de cocina de acuerdo con las normas UL 142 o UL 80 y deben instalarse según las instrucciones del fabricante del tanque.

319.8.2 Tanques no metálicos. Los tanques de almacenamiento de aceite de cocina no metálicos deben instalarse de acuerdo con las instrucciones del fabricante del tanque y, además, deben cumplir con todo lo siguiente:

1. Los tanques deben incluirse en el listado para su uso con aceite de cocina, incluida la temperatura máxima a la que estarán expuestos los tanques durante el uso.
2. La capacidad de cada tanque no debe superar los 200 galones (757 l).

319.8.3 Componentes del sistema de almacenamiento de aceite de cocina. Los componentes metálicos y no metálicos de los sistemas de almacenamiento de aceite de cocina deben incluir tuberías, conexiones, conectores, válvulas, tubos, mangueras, bombas, sistemas de ventilación y otros componentes relacionados que se utilicen para la transferencia de aceite de cocina.

319.8.4 Criterios de diseño. El diseño, la fabricación y el ensamblaje de los componentes del sistema deben ser adecuados para las presiones de operación, las temperaturas y las tensiones estructurales a las que se sometan los componentes.

319.8.5 Ventilación del tanque. Se debe proporcionar ventilación normal y de emergencia para los tanques de almacenamiento de aceite de cocina.

319.8.5.1 Ventilaciones normales. Las ventilaciones normales deben ubicarse por encima de la línea de líquido normal máxima y tener un área eficaz mínima no menor que la conexión de llenado o descarga más larga. No se requiere que las ventilaciones normales ventilen al exterior.

319.8.5.2 Ventilaciones de emergencia. Las ventilaciones de alivio de emergencia deben colocarse por encima de la línea de líquido normal máxima y deben tener la forma de un dispositivo de alivio de presión interna excesiva provocada por la exposición al fuego. En el caso de los tanques no metálicos, se permitirá una ventilación de alivio de emergencia en su forma de construcción. No se requiere que las ventilaciones de emergencia ventilen al exterior.

319.9 Sistemas de gas licuado de petróleo (gas LP). Cuando los sistemas de gas LP suministren combustible a los artefactos de cocina, dichos sistemas deben cumplir con el capítulo 61 y las secciones 319.9.1 a 319.9.5 de la NFPA 58.

319.9.1 Volumen total máximo. La capacidad total máxima de los contenedores de gas LP transportados por el vehículo y que se usan únicamente para alimentar artefactos de cocina no debe superar la capacidad de 200 libras de propano.

319.9.2 Protección del contenedor. Los contenedores de gas LP instalados en el vehículo deben montarse y sujetar de forma segura para evitar que se muevan.

319.9.3 Construcción de contenedores de gas LP. Los contenedores de gas LP deben fabricarse de conformidad con los requisitos de la NFPA 58.

319.9.4 Protección del sistema de tuberías. El sistema de tuberías de gas LP, incluidas las válvulas y los conectores, deben estar debidamente protegidos para evitar la manipulación, el daño por impacto y el daño por vibración.

319.9.5 Alarmas de gas LP. Se debe instalar una alarma de gas LP autorizada en el vehículo en la proximidad de los componentes del sistema de gas LP, de acuerdo con las instrucciones del fabricante.

319.10 Sistemas de gas natural comprimido (GNC). Cuando los sistemas de GNC suministren combustible a los artefactos de cocina, dichos sistemas deben cumplir con las secciones 319.10.1 a 319.10.4.

319.10.1 Contenedores de GNC que únicamente suministran combustible para cocinar. Los contenedores de GNC instalados exclusivamente para el suministro de combustible para cocinar deben cumplir con las secciones 319.10.1.1 a 319.10.1.3.

319.10.1.1 Volumen total máximo. La capacidad total máxima de los contenedores de GNC transportados por el vehículo no debe superar la capacidad de 1,300 libras de agua.

319.10.1.2 Protección del contenedor. Los contenedores de GNC se deben montar y sujetar de forma segura para evitar que se muevan. Los contenedores no deben instalarse en lugares sometidos al impacto directo del vehículo.

319.10.1.3 Construcción de contenedores de GNC. Se debe aprobar la construcción de los contenedores de GNC.

SÓLIDOS Y LÍQUIDOS REACTIVOS AL AGUA

319.10.2 Contenedores de GNC que suministran combustible para transporte y cocina. Cuando los contenedores y los sistemas de GNC se usen para suministrar combustible para cocinar, además de usarlo para el transporte, la instalación debe realizarse de acuerdo con la NFPA 52.

319.10.3 Protección del sistema de tuberías. Los sistemas de las tuberías de GNC, incluidas las válvulas y los conectores, deben protegerse adecuadamente para evitar manipulaciones, daños por impacto y daños por vibración.

319.10.4 Detectores de gas metano. Dentro del vehículo, debe instalarse un detector de gas metano aprobado según las instrucciones del fabricante.

319.11 Mantenimiento. El mantenimiento de los sistemas en vehículos móviles para preparación de alimentos debe realizarse de acuerdo con lo establecido en las secciones 319.11.1 a 319.11.3.

319.11.1 Sistema de extracción. El sistema de extracción, incluida la campana, los dispositivos de eliminación de grasa, los ventiladores, los conductos y otros accesorios, se deben inspeccionar y limpiar de conformidad con el capítulo 6.

319.11.2 Sistemas y dispositivos de protección contra incendios. Los sistemas y dispositivos de protección contra incendios se deben mantener de conformidad con el capítulo 9.

319.11.3 Sistemas de gas combustible. Los contenedores de gas LP instalados en el vehículo y los sistemas de tuberías de gas combustible deben ser examinados de forma anual por una agencia de inspección autorizada o por una compañía inscrita en el Departamento de Transporte de los Estados Unidos, para recalificar cilindros de gas LP, a fin de garantizar que los componentes del sistema estén libres de daños, sean adecuados para el servicio previsto y no tengan fugas. Los contenedores de GNC deben inspeccionarse cada tres años en un centro de reparación que cumpla los requisitos. Los contenedores de GNC no deben usarse tras las fechas de vencimiento que figuran en la etiqueta del envase del fabricante. Luego de aprobada la inspección, la agencia de inspección autorizada debe colocar una etiqueta en el sistema de gas combustible o en el vehículo, con el nombre de la agencia de inspección y la fecha de aprobación de la inspección.